

This matter is being dealt with by:
Ross Marshall
Tel: 0115 977 4473
E-mail: Ross.marshall@nottscc.gov.uk



Planning ref: 20/00873/FULM
Our ref: 19/20-233
Consultation received: 11/08/20

Matt Lamb
Director of Growth and Regeneration
Newark and Sherwood District Council
Castle House
Great North Road
Newark
NG24 1BY

FAO Application Case Officer

26 August 2020

Dear Matt Lamb

PROPOSAL: Residential development of 103 dwellings and associated access and infrastructure

LOCATION: Eakring Road, Bilsthorpe,

Nottinghamshire County Council as the Lead Local Flood Authority (LLFA) has reviewed the application which was received on the 11 Aug 2020. Based on the submitted information we have no objection to the proposals and can recommend approval of planning subject to the following conditions;

Condition

No part of the development hereby approved shall commence until a detailed surface water drainage scheme based on the principles set forward by the approved Travis Barker Flood Risk Assessment (FRA) and Drainage Strategy Addendum Report has been submitted to and approved in writing by the Local Planning Authority in consultation with the Lead Local Flood Authority. The scheme shall be implemented in accordance with the approved details prior to completion of the development. The scheme to be submitted shall:

- Demonstrate that the development will use SuDS throughout the site as a primary means of surface water management and that design is in accordance with CIRIA C753.
- Limit the discharge rate generated by all rainfall events up to the 100 year plus 40% (for climate change) critical rain storm 5 l/s rates for the developable area.
- Provision of surface water run-off attenuation storage in accordance with 'Science Report SCO30219 Rainfall Management for Developments' and the approved FRA
- Provide detailed design (plans, network details and calculations) in support of any surface water drainage scheme, including details on any attenuation system, and the outfall arrangements. Calculations should demonstrate the performance of the designed system for a range of return periods and storm durations inclusive of the 1 in 1 year, 1 in 2 year, 1 in 30 year, 1 in 100 year and 1 in 100 year plus climate change return periods.
- For all exceedance to be contained within the site boundary without flooding new properties in a 100year+40% storm.

View our privacy notice at www.nottinghamshire.gov.uk/privacy

Nottinghamshire County Council, County Hall, West Bridgford, Nottingham NG2 7QP

- Details of STW approval for connections to existing network and any adoption of site drainage infrastructure.
- Evidence of how the on-site surface water drainage systems shall be maintained and managed after completion and for the lifetime of the development to ensure long term

Reason

A detailed surface water management plan is required to ensure that the development is in accordance with NPPF and local planning policies. It should be ensured that all major developments have sufficient surface water management, are not at increased risk of flooding and do not increase flood risk off-site.

Informative

We ask to be re-consulted with any changes to the submitted and approved details of any FRA or Drainage Strategy which has been provided. Any deviation from the principles agreed in the approved documents may lead to us objecting to the discharge of conditions. We will provide you with bespoke comments within 21 days of receiving a formal consultation.

Yours sincerely

Ross Marshall

Ross Marshall
Principal Flood Risk Management Officer

Please ensure any consultations are sent to flood.team@nottsc.gov.uk